



# WELL DISINFECTION

## DRILLED WELL

Diameter of Well (in inches)	Gallons (per foot of water)	Amount of Disinfectant Required for each 100 gallons of water
3	.37	Laundry Bleach (5.25% Chlorine) 3 cups*  Hypochlorite Granules (70% Chlorine) 2 ounces**  *1 cup equals 8-ounce measuring cup ** 1 ounce equals 2 heaping tablespoons of granules
4	.65	
5	1.00	
6	1.50	
8	2.60	
10	4.10	
12	6.00	

## DUG WELL

Diameter of Well (in feet)	Amount of 5.25 laundry bleach per foot of water	Amount of 70% Chlorine Granules per foot of water
3	1-1/2 cups	1 ounce
4	3 cups	2 ounces
5	4-1/2 cups	3 ounces
6	6 cups	4 ounces
7	9 cups	6 ounces
8	12 cups	8 ounces
10	18 cups	12 ounces

Revised June 13, 2008